



TEST CERTIFICATE

1st Floor Building 550 Winch Road Kent Science Park Sittingbourne Kent ME9 8EF England
Telephone: 0844 7250742

Page 1 of 1

Mrs Cara Cook
4i Water Services Ltd
Unit 17 (next door to unit 18)
Woolpit Business Park
Woolpit
Bury St Edmunds, Suffolk
IP30 9UP
Fax: 01359 244 405

Certificate Number: TSBN1842692-1 Final
Date Reported: 31/07/2023
Date Analysis Started: 20/07/2023
Order Number:

Lab Ref.	Sample Details	Method Number	Test	Result	Units	Flag
SBN6964649	Rcvd Dt:: 20/07/2023 Description: Melbourn Parish Council The Sport Pavillion - Kitchen HWS Date / Time Sampled: 17/07/2023 10:00	BIO114	Legionella spp.	Not Detected	In volume tested	-
		BIO114	Limit of Detection	100	cfu in volume tested	-
		BIO114	Legionella - Volume Filtered	1000	ml	-

Certificate approved and electronically signed on 31/07/23 16:28

By Marcin Kruk, Laboratory Manager

For and on Behalf of ALS Laboratories (UK) Limited

Disclaimers:

The testing results in this certificate relate only to the samples described above.
Unless otherwise stated, all results are expressed on an as received basis.
Statement of conformity made against the result does not take into account the uncertainty of measurement associated to the method.
Opinions and interpretations expressed herein are outside the scope of UKAS accreditation.
Time of Sampling; 00:00 indicates no time of sampling has been supplied.



1282