

Hi

See attached results and photos. they are all asbestos.

Its extremely likely that there is asbestos throughout the whole area as its very common here. The old asbestos factory was so close by at Meldreth. They used to sell the broken pieces as hard core.

Im sorry to say that this would be an expensive exercise. If someone can estimate how many tonnes needs to be removed from site we can give a price

Barry





CERTIFICATE FOR IDENTIFICATION OF ASBESTOS FIBRES

STANDARD	
PREMIUM	
EMERGENCY	

Client:	CAMBRIDGE ASBESTOS REMOVAL
Address:	KINGS VIEW QUEENS LANE CHEVINGTON, BURY ST EDMUNDS SUFFOLK, IP29 5RF
Attention:	TECHNICAL MANAGER
Site Address:	LITTLE HANDS NURSERY THE MOOR MELBOURN
Date sample taken:	UNKNOWN
Date sample received:	11/04/24
Date of Analysis:	11/04/24

Analysis Report No.	SCO/24/10988		
Report Date.	11/04/24		
Site Ref No.	N/A		
Page No:	1	Of	1
No. of Samples:	3		
Obtained:	DELIVERED		

Samples of material, referenced below, have been examined to determine the presence of asbestos fibres, using Scopes Asbestos Analysis "in house" method of transmitted/polarised light microscopy and centre stop dispersion staining, based on HSE's HSG248. If samples have been DELIVERED the site address and actual sample location is as given by the client at the time of delivery. Scopes Asbestos Analysis Services Limited are not responsible for the accuracy or competence of the sampling by third parties. Under these circumstances Scopes Asbestos Analysis Services Limited cannot be held responsible for the interpretation of the results shown. Results relate only to the items tested.

SCOPE'S SAMPLE No.	CLIENT SAMPLE No.	Sample Location	Fibre Type Detected
1	1	GRASS CLEAR AREA NEAR CARPARK	CHRYSTOTILE
2	2	GRASS CLEAR AREA MIDWAY	CHRYSTOTILE
3	3	GRASS CLEAR AREA FAR	CHRYSTOTILE

KEY: NADIS – No Asbestos Detected in Sample

Note: All samples will be retained for a minimum of six months. Reports & Records are retained for a minimum of 5 years.

Note: This Certificate for Identification of Asbestos Fibres shall not be reproduced except in full without the written approval of the Laboratory.

Note: All Analysis is performed in House on the registered premises (below).

Note: Where an 'A' appears at the end of the analysis report number this means an amendment has been made to the original report. Information that has been amended will be marked with an *

Analysed by:	S GIDDINGS	Authorised signatory:	
		Print name:	C.BOLTON – DEPUTY Q.C.M
BULK 001-VER 8 14-JUN-22-QCM			