

Certificate of Analysis



Customer

4I Water Services
Unit 17 Woolpit Business Park
BSE
IP30 9UP
United Kingdom

Sample Date:* 24/07/2026
Sample Received: 25/07/2026
Analysis Commenced: 25/07/2026
Analysis Complete: 04/08/2026
Order No:* 16815
Job No: 26-026851

Site Name:* Sports Pavillion

Sampled By:* CF

Lab Sample Number	Sample Description*	Deviation Codes	Other ID*	Sample Type*	Sampled Time*	Temp*	CIO2	Final Legionella cfu (10 days) cfu/volume MM-004	Interim Legionella cfu (5 days) cfu/volume MM-004	Limit of Detection cfu/1000ml MM-004	Volume Filtered ml MM-004
1801795	Furthest HWS Sentinel (NOT BLENDED) kitchenette		1 MPC SP	DW	1155	53.8	N/A	Not Detected	Not Detected	50	1000

Approved by:



Date of Issue: 04/08/2026

Tests marked \$ in this report are subcontracted. Tests marked X are out of specification. Tests marked # in this report are not included in the UKAS Accreditation Schedule for our Laboratory. Deviations may affect result validity; Codes: A - No Sample Date provided, B - No Sample Time Provided, C - Sample provided in wrong container, D - Storage temperature, F - Exceeds Sampling to Receipt Time, G - Sample Tested Outside of Permitted Times, H - Samples incubated outside of time period. Sampling, opinions and interpretations expressed herein are outside the scope of UKAS accreditation. Method details and performance characteristics are available on request. < = Less than, > = greater than. All client supplied data is outside our scope and can affect the validity of results. This includes sampling date/time, sample location and items marked *. TVC analysis with results >3000cfu/ml and Pseudomonas species >100cfu/100ml are regarded as an estimate determined by calculation. Please refer to your SLA/supplementary documentation regarding Statements of Conformity and Decision rules applied. Please refer to your UoM supplementary documentation regarding Uncertainty of Measurement for all analytical methods. Results relate only to the items tested. Results apply to the sample(s) as received. Sampling procedures employed are outside the scope of this UKAS accreditation. This certificate shall not be reproduced, except in full, without permission of the laboratory. Registered in England and Wales No. 11506820.

Testing Laboratory

Alpha Scientific, Kent Science Park, Sittingbourne, ME9 8HL E: commercialtesting@adey.com T: 01795 859 623



8901

Page: 1 of 1